

**MONTGOMERY TOWNSHIP BOARD OF EDUCATION**  
**Skillman, New Jersey 08558**

**Meeting, Tuesday, July 19, 2016**

**6:30 p.m. Executive Session**

**7:30 p.m. Public Session**

**Administration Building Large Conference Room**

**WORKSHOP AND BUSINESS MEETING A G E N D A**

**3.0 FINANCE**

**3.13 Approval of change order** to approve the following change order:

Contract:	Kitchen Piping Repairs at the Upper Middle School
Contractor:	Tri-Form Construction, Inc.
Change Order Number:	001
Change Order Amount:	Time and Material not to exceed \$26,500

Description: Additional labor and materials necessary to address the existing under floor electric in the kitchen in order to facilitate the under slab work as follows:

- Supply and install a new temporary feed wire from MDP to KP (100 amp main disconnect) so that the freezers with the food in them remain running.
- Disconnect and pull back existing feeder wire to Kitchen Panel so that concrete slab may be cut safely.
- Disconnect and pull existing feeder wire to dishwasher booster heater panel so that concrete may be cut safely.
- Disconnect and pull back all existing underfloor wiring from equipment locations to Kitchen Panel (KP) to allow safe cutting/digging in the work areas.
- Make repairs as required to damaged conduits. After repairs are made, pull existing wire back in and terminate
- Test electric in kitchen for proper operation after floor is repaired.
- Apply for permit with township for additional work (fees not included)
- Perform additional saw cutting, concrete removal, excavation, backfill, concrete patching and tile repair as needed to accommodate the electrical repairs.
- Disposal of the additional debris as required

This change order will add 10 days to the original project completion date.